



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Component intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 04ATEX1357U** Issue: **8**

4 Component: **Type MSH *** and MSH-P*** Gas Sensors**

This Safety Related Device has been assessed with reference to the requirements of EN 50271:2010. It can be considered for use in the design of safety function up to and including SIL 1 and is not implicit of the achieved Safety Integrity Level (SIL) of the safety related system.

5 Applicant: **Dynament Limited**

6 Address: Hermitage Lane Industrial Estate, Mansfield, Nottingham, NG18 5ER UK

7 This component and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., Notified Body Number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of a component intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

- EN 60079-0:2012+A11:2013 EN 60079-11:2012 (For guidance on the small component tests)
- EN 60079-1:2014 EN 60079-26:2015 (For details on the use of two independent levels of protection)
- EN 50271:2010

10. The sign 'U' is placed after the certificate number to indicate that the product assessed is a component and may be subject to further assessment when incorporated into equipment. Any limitations of use are listed in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified component. If applicable, further requirements of this Directive apply to the manufacture and supply of this component.

12 The marking of the component shall include the following:

Type MSH * and Type MSH-P *** Gas Sensors**

	I M2	and		II 2 G
	Ex db I Mb			Ex db IIC Gb

Type MSHia * and Type MSHia-P *****

	I M1	and		II 2 G
	Ex db+ia I Ma			Ex db IIC Gb

Project Number 0792

Signed:

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 04ATEX1357U
Issue 8

13 DESCRIPTION OF COMPONENT

The Type MSH *** Gas Sensors are a range of 'plug-in' sensors which may be rated at up to 30 V with a maximum power dissipation of up to 0.8 W. The sensors comprise a small cylindrical enclosure manufactured in stainless steel with integral electrical connection pins at the rear and a stainless steel sinter at the front to facilitate the ingress of the sample gas.

The interior of the enclosure comprises a small chamber which may contain a range of electro-catalytic, infrared or pyroelectric gas detectors, all with energy storage capability no greater than 0.04 mJ.

Design option: The sinter may be replaced by a two-layer mesh; this variant is known as the Type MSH-P *** Gas Sensor.

Variation 1

This variation introduced the following changes:

- i. The applicant's name and address was changed:
From: Status Scientific Controls Ltd
Hermitage Lane Industrial Estate, Mansfield, Nottinghamshire NG18 5ER, UK
To: Dynamment Limited
Premier House, The Village, South Normanton, Derbyshire DE55 2DS, UK
- ii. The documents listed in Section 9 were changed to recognise that the sensor complies with the requirements of EN 60079-0:2006 and EN 60079-1:2004.
- iii. The use of alternative materials for the closing disc through which the connection pins pass was introduced, the disc may be manufactured from non-metallic materials having a tracking index greater than CTI 175 or may be manufactured from metal; a special condition for safe use applies.
- iv. All previously certified drawings were replaced by new drawings.

Variation 2

This variation introduced the following changes:

- i. The introduction of the Gas Sensors Type MSHia *** and Type MSHia-P ***, this involved changing the coding for Group I gases and by specifying that the devices shall be supplied by an intrinsically safe supply coded EEx ia (or Ex ia) having a maximum output voltage of 6.0 V d.c. and a maximum output power of 0.8 W.

Variation 3 - This variation introduced the following changes:

- i. Following appropriate re-assessment to demonstrate compliance with the requirements of the latest EN 60079 series of standards, the documents originally listed in section 9, EN 60079-0:2006, EN 60079-1:2004, EN 60079-11:2007 and IEC 60079-26:2006, were replaced by those currently listed.

Variation 4 - This variation introduced the following changes:

- i. It was recognised that the Type MSHia-P *** Gas Sensors can be used as a SIL 1 safety related device as defined in EN 50271:2010; note that the EHSRs section 1.5 (safety related devices) has been addressed, however, performance test to EN 60079-29-1 has not been conducted as part of this certification. This change necessitated the introduction of conditions of manufacture and additional special conditions for safe use.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

**Sira 04ATEX1357U
Issue 8**

Table 1: Summary of Failure Data of Platinum Gas Detector (Single and Dual Channels)

Safety Function:			
To measure the concentration of gas by means of analogue and /or digital outputs so that:			
Analogue output: Output voltage < 0.2V or >2.5V reserved for revealed failures			
Analogue output: Output voltage ≥0.2V and ≤2.5V normal operating conditions			
Digital output: < -200% and/or > 200% of gas concentration reserved for revealed failures			
Digital output: >-200% and < 200% of gas concentration for normal operating conditions			
Notes: For bridge type sensors configuration powered by 5V to 3V, the output Voltage Vo is configurable as defined in this equation:			
Output Voltage (Vo) = (Zero * Supply Voltage) + (Sensitivity * (Gas Level / FSD))			
Where, zero (0.4 to 0.6), Supply Volt (3V to 5V), Sensitivity (±0.1V to ±0.2V), Gas Level (any value between -200% to +200%), FSD (5% v/v)			
(Sensitivity 100mV)			
a)	5V supply voltage:	Vo < 2.3V or >2.7V reserved for revealed failures and Vo ≥2.3V and ≤2.7V normal operating conditions	
b)	3V supply voltage:	Vo < 1.3V or >1.7V reserved for revealed failures and Vo ≥1.3V and ≤1.7V normal operating conditions	
(Sensitivity: 200mV)			
a)	5V supply voltage:	Vo < 2.1V or >2.9V reserved for revealed failures and Vo ≥2.1V and ≤2.9V normal operating conditions	
b)	3V supply voltage:	Vo < 1.1V or >1.9V reserved for revealed failures Vo ≥1.1V and ≤1.9V normal operating conditions	
Digital outputs (SF) conditions unchanged, their outputs as described above.			
Summary of Clauses 7.4.2 and 7.4.4 of IE 61508-2		Single Channel	Dual Channel
Architectural constraints		HFT=0	HFT=0
Safe Failure Fraction (SFF)		66%	67%
Random hardware failures: [h ⁻¹] (dangerous)	λ _{DD} λ _{DU}	1.70E-07 9.20E-08	1.56E-07 8.81E-08
Random hardware failures: [h ⁻¹] (safe)	λ _{SD} λ _{SU}	3.61E-09 7.59E-09	2.05E-09 2.19E-08
Diagnostic Coverage (DC)		64%	64%
Probability of failure on demand @ proof test interval = 8760 Hrs Mean time to restoration = 8 Hrs		4.05E-04	3.88E-04
Frequency of a Dangerous failure (High Demand - PFH) [h ⁻¹]		9.20E-08	8.81E-08
Hardware safety integrity compliance		Route 1 _H	
Systematic safety integrity compliance (HW)		Route 1 _S	
Systematic safety integrity compliance (SW)		EN 50271	
Systematic Capability (SC1, SC2, SC3, SC4)		SC1	
Overall SIL-capability achieved		SIL 1 due to Architectural constraints (SFF).	



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 04ATEX1357U
Issue 8

Variation 5 - This variation introduced the following changes:

- i. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, EN 60079-0:2009, EN 60079-1:2007, EN 60079-11:2007 and EN 60079-26:2007 were replaced by EN 60079-0:2012+A11:2013, EN 60079-1:2014, EN 60079-11:2012 and EN 60079-26:2015, the markings were updated accordingly to recognise the new standards.
- ii. The Applicant's address was changed from Premier House, The Village, South Normanton, Derbyshire, DE55 2DS, UK to Hermitage Lane Industrial Estate, Mansfield, Nottingham, NG18 5ER United Kingdom.
- iii. The product name was modified from Type MSH*** Gas Sensors to MSH*** and MSH-P*** Gas Sensors to align with corresponding IECEx certificate.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	16 November 2004	R51A11650A	The release of prime certificate.
1	18 May 2005	R51V13273A	The re-issue of the prime certificate to recognise the changes described in report number R51V13273A.
2	23 April 2007	R51A16373A	This Issue covers the following changes: <ul style="list-style-type: none"> • All previously issued certification was rationalised into a single certificate Issue 2, Issues 0 and 1 referenced above are only intended to reflect the history of the previous certification and have not been issued as documents in this format. • The introduction of Variation 1.
3	8 August 2008	R52L18475B	The introduction of Variation 2.
4	19 December 2008	R52A19455A	This Issue covers the following changes: <ul style="list-style-type: none"> • Drawings were updated to include the marking 'II 2G'. • The correction of typographical errors.
5	13 April 2010	R21767A/00	The introduction of Variation 3.
6	26 June 2014	R70004928A	The introduction of Variation 4.
7	05 September 2017	R70123584A	This Issue covers the following changes: <ul style="list-style-type: none"> • EC-Type Examination Certificate in accordance with 94/9/EC updated to EU-Type Examination Certificate in accordance with Directive 2014/34/EU. <i>(In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC-Type Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.)</i> • The introduction of Variation 5.
8	April 2019	0792	Transfer of certificate Sira 04ATEX1357U from Sira Certification Service to CSA Group Netherlands B.V..

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 04ATEX1357U
Issue 8

15 SCHEDULE OF LIMITATIONS

- 15.1 The sensors have been assessed as suitable for use within an ambient temperature range of -20°C to +60°C, whilst producing a maximum external surface rise of 45K in normal operation.
- 15.2 The devices shall be effectively protected from impact.
- 15.3 These devices are intended for use at atmospheric pressure and should not be used in pressures exceeding 1.1 bar.
- 15.4 The sensor may be supplied with a metallic closing disc around the connection pins, this shall be considered in respect of creepage and clearance distance when the device is incorporated into equipment.
- 15.5 Unless subsequently protected by concepts that render the following conditions unnecessary:
- The connection pins shall be protected from dust and moisture by an enclosure with an Ingress Protection rating of at least IP 54.
 - The devices should not be installed/removed when an explosive gas atmosphere is present.
- 15.6 The Type MSHia *** and Type MSHia-P *** shall be supplied by an intrinsically safe supply coded EEx ia (or Ex ia) with a maximum output voltage of 6.0 Vd.c. and a maximum output power of 0.8 W.

The following conditions apply when the Types MSH-P* and MSHia-P *** Gas Sensors are used as a SIL 1 safety related device as defined in EN 50271:2010**

- 15.7 The user shall comply with the requirements given in the manufacturer's user documentation in regard to all relevant functional safety aspects such as application of use, installation out of hazardous areas, operation, maintenance, proof tests, maximum ratings, environmental conditions, and repair.
- 15.8 Selection of this equipment for use in safety functions, configuration, overall validation, maintenance and repair shall only be carried out by competent personnel, observing all the manufacturer's conditions and recommendations in the user documentation.
- 15.9 The safety related device must be functioning and powered independently of any control devices required for operation.
- 15.10 The recommended proof test interval for the safety functions is 1 year.
- 15.11 All information associated with any field failures of this product should be collected under a dependability management process (e.g., IEC 60300-3-2) and reported to the manufacturer.
- 15.12 The IR Platinum Series are only approved for software version (V7.17.00u B18).
- 15.13 The certified products series shall only be configured using Dynamant "Status Scientifics' PC application v3.4.0 or later".
- 15.14 The serial communication bus shall only be used with the protocol developed by Dynamant Ltd to exercise the safety function.

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

Certificate Annexe



Certificate Number: Sira 04ATEX1357U
Component: Type MSH *** and MSH-P*** Gas Sensors
Applicant: Dynamment Limited

Issue 0

The drawings introduced in Issue 0 were replaced by the drawings introduced in Issue 1.

Issue 1

The drawings introduced in Issue 1 were replaced by the drawings introduced in Issue 2.

Issue 2

Number	Sheet	Rev.	Date	Description
DYN/015*	1 of 1	1	15 Mar 07	GA sensor housing
DYN/016*	1 of 1	1	15 Mar 07	GA of mini sensor housing
DYN/365	1 of 1	1	15 Mar 07	MSH-P Optic Spacer

* These drawings were replaced by corrective drawings introduced by Issue 3, the replacement drawings bear the Sira date stamp 29 July 2008.

Issue 3

Number	Sheet	Rev.	Date (Sira Stamp)	Description
DYN/016	1 of 1	1	29 Jul 08	General arrangement of Type MSH ***
DYN/015	1 of 1	1	29 Jul 08	General arrangement of Type MSH-P ***
DYN/022	1 of 1	1	10 Jul 08	General arrangement of Type MSHia ***
DYN/021	1 of 1	1	10 Jul 08	General arrangement of Type MSHia-P ***

Issue 4

Number	Sheet	Rev.	Date (Sira Stamp)	Description
DYN/016	1 of 1	2	18 Dec 08	General arrangement of Type MSH ***
DYN/015	1 of 1	2	18 Dec 08	General arrangement of Type MSH-P ***
DYN/022	1 of 1	2	18 Dec 08	General arrangement of Type MSHia ***
DYN/021	1 of 1	2	18 Dec 08	General arrangement of Type MSHia-P ***

Issue 5 No new drawings were introduced.

Issue 6

Number	Sheet	Rev.	Date (Sira Stamp)	Description
FS101	-	1a	01/05/2013	Single channel parts list
FS102	-	1b	01/05/2013	Dual channel parts list
DYN 118	-	3	01/05/2013	Circuit diagram for single channel processor board
DYN 116	-	3	01/05/2013	Circuit diagram for dual channel analogue board
DYN 115	-	2	01/05/2013	Circuit diagram for dual channel processor board
DYN 114	-	3	01/05/2013	Circuit diagram for single channel analogue board

Issue 7

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
DYN/015	1 of 1	3	24 Jul 17	G.A of Exd Sensor Housing type MSH-P
DYN/016	1 of 1	3	24 Jul 17	G.A of Mini Exd Sensor Housing type
DYN/021	1 of 1	3	24 Jul 17	G.A of Exd Sensor Housing type MSHia-P
DYN/022	1 of 1	3	24 Jul 17	G.A of Mini Exd Sensor Housing type MSHia

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands